

## **1 General Information**

Facility /System Name: Town of Wilkesboro Sewer Collection System

Responsible Entity: Town of Wilkesboro

Person in Charge: Jason Hart

Application Permit(s): WQCS000051

### **Description of Collection System or Treatment Process**

The Town of Wilkesboro owns and maintains approximately 61.3 miles of sewer outfall, trunk, and lateral lines with 1.6 miles of force mains.

Pipe Sizes range from 2" up to 24". The pipe materials include VCP, Ductile Iron, PVC, and HDPE.

The Collections System contains 1415 Manholes.

The Collections System contains 5 Lift Stations.

We also help maintain (if needed) 8.11 miles of gravity sewer, 6.9 miles of force sewer, and 136 Manholes of private lines.

## **2 Performance**

### **Text Summary of System Performance for the calendar year of 2025**

The system has performed very well in the last 12 months. There have been 4 violations, All **Non-reportable** for the year. A continuous effort of preventive maintenance and public education by the Town enables this system to perform at a high level.

**List by month any violations of permit conditions of other environmental regulations. Monthly lists should discuss any environmental impacts and measures taken to address violations.**

**First Occurrence** was on 1-30-25 at SGM-416. There were No Excessive Environmental Impacts, Basic clean up procedures were taken. Approx 100 – 200 gallons (non-reportable). This was due to roots, was jetted, and treated to remove the roots.

**Second Occurrence** was on 3-21-25 at SMH-1309. Ther were No Excessive Environmental Impacts, Basic clean up procedures were taken. Approx 200 gallons (non-reportable). This was due to millings from asphalt contractors being in the line.

**Third Occurrence** was on 5-28-25 at SMH-521. There were No Excessive Environmental Impacts. Basic clean up procedures were taken. Less than 200 gallons (non-reportable).

Educated NCDOT about contractors losing loose material into manholes when removing them in preparation for milling.

**Fourth Occurrence** was on 12-23-25 at SGM1163. There were No Excessive Environmental Impact. Basic clean up, Procedures were taken. Approx 400 gallons (non-reportable). This was due to roots, was jetted and treated to remove roots.

### **3 Notification**

**State how this report had been made available to users or customers of the system and how those users have been notified of its availability.**

Copies of this report may be obtained at the Public Works Dept. at 1302 N. Collegiate Dr, Wilkesboro, NC 28697. Notice will also be posted on the Town's website.

### **4 Certification**

I certify that under the penalty of law that this report is complete and accurate to the best of my knowledge.

I further certify that this report has been made available to the users or customers of the named system.



Jason Hart, ORC

Town of Wilkesboro