



2009 Annual Drinking Water Quality Report

Town of Wilkesboro

PWS ID # 01-97-025

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is a snapshot of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water and to providing you with this information, because informed customers are our best allies. If you have any questions about this report or concerning your water, please contact the Town of Wilkesboro Water Filtration Plant at 838-4631. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled Town Board Meetings. They are held on the first Monday of each month at 7.00 P.M. at Wilkesboro Town Hall.

What EPA Wants You to Know

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Wilkesboro is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at [Http://www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems; and radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

When You Turn on Your Tap, Consider the Source

The water that is used by this system is surface water from the Yadkin River. Our intake is located adjacent to North Collegiate Drive.

Source Water Assessment Program (SWAP) Results

The North Carolina Department of Environment and Natural Resources (DENR), Public Water Supply (PWS) Section, Source Water Assessment Program (SWAP) conducted assessments for all drinking water sources across North Carolina. The purpose of the assessments was to determine the susceptibility of each drinking water source (well or surface water intake) to Potential Contaminant Sources (PCSs). The results of the assessment are available in SWAP Assessment Reports that include maps, background information and a relative susceptibility rating of Higher, Moderate or Lower.

The relative susceptibility rating of each source for Town of Wilkesboro water system was determined by combining the contaminant rating (number and location of PCSs within the assessment area) and the inherent vulnerability rating (i.e., characteristics or existing conditions of the well or watershed and its delineated assessment area.). The assessment findings are summarized in the table below:

Susceptibility of Sources to Potential Contaminant Sources (PCSs)

Source Name	Susceptibility Rating	SWAP Report Date
Yadkin River	Higher	05/16/2007

The complete SWAP Assessment report for Town of Wilkesboro may be viewed on the Web at: <http://www.deh.enr.state.nc.us/pws/swap> Please note that because SWAP results and reports are periodically updated by the PWS Section, the results available on this web site may differ from the results that were available at the time this CCR was prepared. If you are unable to access your SWAP report on the web, you may mail a written request for a printed copy to: Source Water Assessment Program – Report Request, 1634 Mail Service Center, Raleigh NC 27699-1634, or email requests to swap@ncmail.net. Please indicate your system name (Town of Wilkesboro), PWSID (01-97-025), and provide your name, mailing address and phone number. If you have any questions about the SWAP report please contact the Source Water Assessment staff by phone at 919-715-2633.

It is important to understand that a susceptibility rating of “higher” does not imply poor water quality, only the systems’ potential to become contaminated by PCS’s in the assessment area

Violations that Your Water System Received for the Report Year: None

Water Quality Data Table of Detected Contaminants

We routinely monitor for over 150 contaminants in your drinking water according to Federal and State laws. The table below lists all the drinking water contaminants that we detected in the last round of sampling for the particular contaminant group. The presence of contaminants does not necessarily indicate that water poses a health risk. **Unless otherwise noted, the data presented in this table is from testing done January 1 through December 31, 2009.** The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted.

Important Drinking Water Definitions:

Not-Applicable (N/A) – Information not applicable/not required for that particular water system or for that particular Rule.

Non-Detects (ND) - laboratory analysis indicates that the contaminant is not present at the level of detection set for the particular methodology used.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Action Level (AL) -the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Residual Disinfection Level Goal – The “Level” (MRDLG) of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum Residual Disinfection Level – The “Highest Level” (MRDL) of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Contaminant Level - The “Maximum Allowed” (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology

Maximum Contaminant Level Goal - The “Goal”(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Extra Note: MCL’s are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Microbiological Contaminants

Contaminant (units)	MCL Violation Y/N	Your Water	MCLG	MCL	Likely Source of Contamination
Total Coliform Bacteria (presence or absence)	N	0	0	one positive monthly sample	Naturally present in the environment
Fecal Coliform or E. coli (presence or absence)	N	0	0	0 (Note: The MCL is exceeded if a routine sample and repeat sample are total coliform positive, and one is also fecal coliform or E. Coli positive)	Human and animal fecal waste

Turbidity *

Contaminant (units)	MCL Violation Y/N	Your Water	MCLG	MCL	Likely Source of Contamination
Turbidity (NTU)	N	0.15	N/A	TT = 1 NTU	Soil runoff
		100%		TT = percentage of samples ≤ 0.3 NTU	

* Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system. The turbidity rule requires that 95% or more of the monthly samples must be less than or equal to 0.3 NTU.

Inorganic Contaminants

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
Fluoride (ppm)	11/09	N	1.05	1.05	1.05	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories

Nitrate/Nitrite Contaminants

Contaminant (units)	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
			Low	High			
Nitrate (as Nitrogen) (ppm) 02 / 09	N	ND	N/A		10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

Lead and Copper Contaminants

Contaminant (units)	Sample Date	Your Water	# of sites found above the AL	MCLG	MCL	Likely Source of Contamination
Copper (ppm) (90 th percentile)	06 / 08	< 0.05	0	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead (ppb) (90 th percentile)	06 / 08	< 3	0	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

Radiological Contaminants

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	MCLG	MCL	Likely Source of Contamination
Alpha emitters (pCi/l)	07 / 00	N	0.00	0	15	Erosion of natural deposits
Beta/photon emitters (pCi/l)	07 / 00	N	2.06	0	50 *	Decay of natural and man-made deposits
Combined radium (pCi/l)	07 / 09	N	0.3	0	5	Erosion of natural deposits
Uranium (pCi/l)	Waiver 2012	n/a	-	0	20.1	Erosion of natural deposits

* Note: The MCL for beta particles is 4 mrem/year. EPA considers 50 pCi/L to be the level of concern for beta particles.

Disinfection By-Product Precursors Contaminants

Contaminant (units)	TT Violation Y/N	Your Water (RAA Removal Ratio)	Range Monthly Removal Ratio Low-High	MCLG	MCL	Likely Source of Contamination	Compliance Method (Step 1 or ACC #)
Total Organic Carbon (ppm) (removal ratio) (TOC)-TREATED	N	1.0 *	0.5 – 1.4 *	N/A	TT	Naturally present in the environment	ACC 2

Note: Depending on the TOC in our source water the system MUST have a certain % removal of TOC or must achieve alternative compliance criteria. If we do not achieve that % removal there is an "alternative % removal". If we fail to meet that, we are in violation of a Treatment Technique.

* For systems using Alt. 2 of the Alternative Compliance Criteria, RAA (Running Annual Average) Removal Ratios and Monthly Removal Ratios are replaced with RAA Treated Water TOC and Monthly Treated Water TOC Results.

Alternative Compliance Criteria (ACC)	
Alt. 1	Source Water TOC < 2.0 mg/L
Alt. 2	Treated Water TOC < 2.0 mg/L
Alt. 3	Source Water SUVA \leq 2.0 L/mg-m
Alt. 4	Treated Water SUVA \leq 2.0 L/mg-m
Alt. 5	Treated Water Alkalinity < 60 mg/L (for softening systems only)
Alt. 6	THM & HAA RAA's \leq 1/2 MCL & uses only chlorine
Alt. 7	Source TOC RAA < 4.0 mg/L and Source Alkalinity > 60 mg/L and THM & HAA RAAs \leq 1/2 MCL

STEP 1 TOC Removal Requirements			
Source Water TOC (mg/L)	Source Water Alkalinity Mg/L as CaCO3 (in percentages)		
	0 - 60	>60-120	>120
> 2.0 - 4.0	35.0	25.0	15.0
> 4.0 - 8.0	45.0	35.0	25.0
> 8.0	50.0	40.0	30.0

Disinfection By-Product Contaminants

Contaminant (units)	MCL/MRDL Violation Y/N	Your Water (AVG.)	Range Low High	MCLG	MCL (AVG.)	Likely Source of Contamination
TTHM (ppb) [Total Trihalomethanes]	N	49	31 69	N/A	80	By-product of drinking water chlorination
HAA5 (ppb) [Total Haloacetic Acids]	N	24	19 29	N/A	60	By-product of drinking water disinfection
Chlorine (ppm)	N	1.6	1.0 1.9	MRDLG = 4	MRDL = 4	Water additive used to control microbes

*Disinfection By-Products Maximum Contaminant Levels (MCL's) are calculated as a running annual average

Secondary Contaminants, required by the NC Public Water Supply Section, are substances that affect the taste, odor, and/or color of drinking water. These aesthetic contaminants normally do not have any health effects and normally do not affect the safety of your water.

Water Characteristics Contaminants

Contaminant (units)	Sample Date	Your Water	Range Low/High	Secondary MCL
Sodium (ppm)	11 / 09	11.3	N/A	N/A

Our system monitored for Cryptosporidium once monthly in 2009 as mandated by the new Federal Long Term 2 Enhanced Surface Water Treatment Rule. This rule is designed to assess the susceptibility of source waters to microbiological contaminants and determine if additional treatment is needed by the water system. During the initial monitoring conducted in 2009 ranges for Cryptosporidium detected were between (0 and 0.95 oocysts/L.)

Cryptosporidium is a microbiological parasite, which is found in surface water throughout the U.S. Although Cryptosporidium can be removed by filtration, the most commonly used filtration methods cannot guarantee 100 percent removal. Our monitoring of our source water indicates the presence of these organisms. Current test methods do not enable us to determine if the organisms are dead or if they are capable of causing disease. Symptoms of infection include nausea, diarrhea, and abdominal cramps. Most healthy individuals are able to overcome the disease within a few weeks. However, immuno-compromised individuals are encouraged to consult their doctor regarding appropriate precautions to take to prevent infection. Cryptosporidium must be ingested for it to cause disease, and it may be spread through means other than drinking water.